



BUS MAY BE LOWERED FOR OVERHEAD SERVICE ENTRY

NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. FOR 3Ø 3-WIRE, NEUTRAL BUS IS OMITTED.
4. 65,000 AMP SHORT-CKT RATING
5. 0.100" ALUMINUM CABINET
6. UL LISTED

101
601

REVISIONS		
NO	DATE	BY
1	05/16/96	RCE
2	01/21/97	RCE
3	08/23/99	KAP
4	06/07/00	KAP
5	08/23/02	KAP
6	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

400 AMP TERMINATION BOX ~
IN AC422008

DR BY	DATE	APP'D BY	DR NO.
RCE	12/15/95	RCE	20103-801