



BUS MAY BE LOWERED FOR OVERHEAD SERVICE ENTRY

NOTES:

TB-800-2

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. FOR 3Ø 3-WIRE, NEUTRAL BUS IS OMITTED.
4. 65,000 AMP SHORT-CKT RATING
5. 0.100" ALUMINUM CABINET
6. UL LISTED

104
602

REVISIONS		
NO	DATE	BY
1	05/16/96	RCE
2	01/21/97	RCE
3	06/29/99	KAP
4	08/26/02	KAP
5	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.
STOUGHTON, WISCONSIN

800 AMP TERMINATION BOX ~
IN AC482510

DR BY	DATE	APP'D BY	DR NO.
RCE	12/21/95	RCE	20103-803