



NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 3Ø 3-WIRE, NEUTRAL BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM CABINET
5. UL LISTED

TB-800-3

REVISIONS		
NO	DATE	BY
1	05/16/96	RCE
2	08/19/99	RCE
3	08/26/02	KAP
4	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

800 AMP TERMINATION BOX ~
IN AC543614

DR BY	DATE	APP'D BY	DR NO.
RCE	12/18/95	RCE	20103-804

106
604