



BUS MAY BE LOWERED FOR OVERHEAD SERVICE ENTRY

NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 3Ø 3-WIRE, NEUTRAL BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM CABINET
5. UL LISTED

TB-1600-5

| REVISIONS | | |
|-----------|----------|-----|
| NO | DATE | BY |
| 2 | 01/22/97 | RCE |
| 3 | 08/19/99 | KAP |
| 4 | 06/07/00 | KAP |
| 5 | 08/26/02 | KAP |
| 6 | 05/05/04 | KAP |
| 7 | 02/01/07 | KRE |



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

1600 AMP TERMINATION BOX ~
IN AC603816

| | | | |
|-------|----------|----------|-----------|
| DR BY | DATE | APP'D BY | DR NO. |
| RCE | 12/18/95 | RCE | 20103-806 |

107
604