



BUS MAY BE LOWERED FOR OVERHEAD SERVICE ENTRY

NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 3Ø 3-WIRE, NEUTRAL BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM CABINET
5. UL LISTED

TB-2500-7

REVISIONS		
NO	DATE	BY
1	09/17/97	RCE
2	08/19/99	KAP
3	06/07/00	KAP
4	08/27/02	KAP
5	02/01/07	KRE

RJB GALVA-CLOSURE PRODUCTS CO.
STOUGHTON, WISCONSIN

2500 AMP TERMINATION BOX ~
IN AC724220

108
613

DR BY	DATE	APP'D BY	DR NO.
RCE	01/22/97	RCE	20103-808