


BOTTOM FEED ONLY

TBALI-413-1
TBALI-434-1

NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. FOR 3Ø 3-WIRE, NEUTRAL BUS IS OMITTED.
4. 50,000 AMP SHORT-CKT RATING
5. 0.100" ALUMINUM CABINET
6. UL LISTED

103
602

REVISIONS						
NO	DATE	BY				
1	08/22/99	KAP	400 AMP TERMINATION BOX ~ IN AC482514			
2	06/07/00	KAP				
3	08/27/02	KAP				
4	01/11/07 LUGS	KAP				
5	02/01/07	KRE				
			DR BY	DATE	APP'D BY	DR NO.
			RCE	12/09/96	RCE	20103-811