



TBALI-613-2  
TBALI-634-2

**NOTES:**

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. FOR 3Ø 3-WIRE, NEUTRAL BUS IS OMITTED.
4. 65,000 AMP SHORT-CKT RATING
5. 0.100" ALUMINUM CABINET
6. UL LISTED

103  
602

REVISIONS		
NO	DATE	BY
1	05/16/96	RCE
2	08/26/99	KAP
3	02/01/07	KRE



**GALVA-CLOSURE PRODUCTS CO.**

STOUGHTON, WISCONSIN

600 AMP TERMINATION BOX ~  
IN AC482514

DR BY	DATE	APP'D BY	DR NO.
RCE	12/09/96	RCE	20103-812