



NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 3Ø 3-WIRE, NEUTRAL BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM CABINET
5. UL LISTED

TBALI-1234-5

REVISIONS		
NO	DATE	BY
1	08/22/99	KAP
2	06/07/00	KAP
3	08/28/02	KAP
4	01/09/03	KAP
5	01/11/07 LUGS	KAP
6	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

1200 AMP TERMINATION BOX ~
IN AC543614

DR BY	DATE	APP'D BY	DR NO.
RCE	12/06/96	RCE	20103-814

106
604