


BOTTOM FEED ONLY

NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 3Ø 3-WIRE, NEUTRAL BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM CABINET
5. UL LISTED

TBALI-1634-4

106
604

REVISIONS						
NO	DATE	BY				
1	08/24/99	KAP	1600 AMP TERMINATION BOX ~ IN AC543614			
2	06/07/00	KAP				
3	08/28/02	KAP				
4	02/01/07	KRE				
			DR BY	DATE	APP'D BY	DR NO.
			RCE	12/10/96	RCE	20103-815