


NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 3Ø 3-WIRE, NEUTRAL BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM CABINET

TBALI-3034-8

REVISIONS			 GALVA-CLOSURE PRODUCTS CO. STOUGHTON, WISCONSIN		
NO	DATE	BY			
1	08/30/99	KAP	3000 AMP TERMINATION BOX ~ IN AC724220		
2	06/07/00	KAP			
3	08/29/02	KAP			
4	02/01/07	KRE			
DR BY RCE			DATE 12/10/96	APP'D BY RCE	DR NO. 20103-818

108
613