



NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 3Ø 3-WIRE, NEUTRAL BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM CABINET
5. UL LISTED

105
604

TBWE-813-2
TBWE-833-2
TBWE-834-2

REVISIONS		
NO	DATE	BY
1	03/18/99	KAP
2	04/30/02	RCE
3	04/09/04	KAP
4	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

800 AMP TERMINATION BOX ~
IN AC483614

DR BY	DATE	APP'D BY	DR NO.
RCE	04/21/97	RCE	20103-821