



**NOTES:**

1. 3Ø 4-WIRE SHOWN
2. FOR 3Ø 3-WIRE, NEUTRAL BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM CABINET
5. UL LISTED

106  
604

TBWE-1233-3  
TBWE-1234-3

| REVISIONS |          |     | <b>RJB</b>                                | <b>GALVA-CLOSURE PRODUCTS CO.</b> |          | STOUGHTON, WISCONSIN |  |
|-----------|----------|-----|---|-----------------------------------|----------|----------------------|--|
| NO        | DATE     | BY  |   |                                   |          |                      |  |
| 1         | 08/27/99 | KAP | 1200 AMP TERMINATION BOX ~<br>IN AC543614 |                                   |          |                      |  |
| 2         | 06/07/00 | KAP |   |                                   |          |                      |  |
| 3         | 09/02/02 | KAP |   |                                   |          |                      |  |
| 4         | 02/01/07 | KRE |   |                                   |          |                      |  |
|           |          |     | DR BY                                     | DATE                              | APP'D BY | DR NO.               |  |
|           |          |     | RCE                                       | 04/21/97                          | RCE      | 20103-822            |  |