



**NOTES:**

1. 3Ø 4-WIRE SHOWN
2. FOR 3Ø 3-WIRE, NEUTRAL BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM CABINET
5. UL LISTED

TBWE-1633-4  
TBWE-1634-4

REVISIONS		
NO	DATE	BY
1	08/26/99	KAP
2	06/07/00	KAP
3	09/02/02	KAP
4	02/01/07	KRE



**GALVA-CLOSURE PRODUCTS CO.**

STOUGHTON, WISCONSIN

1600 AMP TERMINATION BOX ~  
IN AC543614

DR BY	DATE	APP'D BY	DR NO.
RCE	04/21/97	RCE	20103-823