



NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.100" ALUMINUM CABINET
5. UL LISTED

TBBXALI-434-1
TBBXALI-413-1

REVISIONS		
NO	DATE	BY
1	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

400 AMP TERM. BOX, BOTTOM EXIT WIREWAY
WITH (1) 2-350 MCM LINE LUG ~ IN AC482514

DR BY	DATE	APP'D BY	DR NO.
KAP	01/11/07	RCE	20103-839