



NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM CABINET
5. UL LISTED

TBBXALI-613-2
TBBXALI-634-2

REVISIONS		
NO	DATE	BY
1	02/01/07	KRE

RJB GALVA-CLOSURE PRODUCTS CO.
STOUGHTON, WISCONSIN

600 AMP TERM. BOX, BOTTOM EXIT WIREWAY
WITH (2) 600 MCM LINE LUGS ~ IN AC483614

DR BY	DATE	APP'D BY	DR NO.
KAP	01/11/07	RCE	20103-840