



**NOTES:**

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM CABINET
5. UL LISTED

TBBXALI-813-3  
TBBXALI-834-3

REVISIONS		
NO	DATE	BY
1	02/01/07	KRE



**GALVA-CLOSURE PRODUCTS CO.**

STOUGHTON, WISCONSIN

800 AMP TERM. BOX, BOTTOM EXIT WIREWAY WITH (3) 600 MCM LINE LUGS ~ IN AC483614

DR BY	DATE	APP'D BY	DR NO.
KAP	10/15/02	RCE	20103-841

161  
602