



NOTES:

1. 3Ø 4-WIRE SHOWN
2. 65,000 AMP SHORT-CKT RATING
3. 0.125" ALUMINUM CABINET
4. UL LISTED

TBBXALI-1234-5

REVISIONS		
NO	DATE	BY
1	01/09/03	KAP
2	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

1200 AMP TERM. BOX, BOTTOM EXIT WIREWAY WITH (5) 600 MCM LINE LUGS ~ IN AC544614

DR BY	DATE	APP'D BY	DR NO.
KAP	10/15/02	RCE	20103-842