



**NOTES:**

1. 3Ø 4-WIRE SHOWN
2. 65,000 AMP SHORT-CKT RATING
3. 0.125" ALUMINUM CABINET
4. UL LISTED

TBBXALI-1634-4

| REVISIONS |          |     |
|-----------|----------|-----|
| NO        | DATE     | BY  |
| 1         | 02/01/07 | KRE |
|           |          |     |
|           |          |     |
|           |          |     |
|           |          |     |
|           |          |     |



**GALVA-CLOSURE PRODUCTS CO.**

STOUGHTON, WISCONSIN

1600 AMP TERM. BOX, BOTTOM EXIT WIREWAY WITH (4) 1000 MCM LINE LUGS ~ IN AC544614

|       |          |          |           |
|-------|----------|----------|-----------|
| DR BY | DATE     | APP'D BY | DR NO.    |
| KAP   | 10/15/02 | RCE      | 20103-843 |

166  
604