



NOTES:

1. 3Ø 4-WIRE SHOWN
2. 65,000 AMP SHORT-CKT RATING
3. 0.125" ALUMINUM CABINET
4. UL LISTED

TBBXALI-3034-8

REVISIONS		
NO	DATE	BY
1	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

3000 AMP TERM. BOX, BOTTOM EXIT WIREWAY WITH (8) 1000 MCM LINE LUGS ~ IN AC725020

DR BY	DATE	APP'D BY	DR NO.
KAP	10/15/02	RCE	20103-846

164
613