



NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM CABINET
5. UL LISTED

GIN
MAE

REVISIONS		
NO	DATE	BY
1	06/01/02	KAP
2	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

800 AMP BUS ~ IN AC483614
UNDERGROUND ENTRANCE & EXIT

DR BY	DATE	APP'D BY	DR NO.
RCE	01/15/98	RCE	20104-768A