



NOTES:

- 3Ø 4-WIRE SHOWN
- FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
- 85,000 AMP SHORT-CKT RATING
- 0.125" ALUMINUM CABINET
- UL LISTED

ALI-1234UGBX

REVISIONS		
NO	DATE	BY
1	01/11/07	KAP
2	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

1200 AMP BUS ~ IN AC544614 WITH 3 LUGS ON TOP & 5 ON BOTTOM, UNDERGROUND ENTRANCE & EXIT

DR BY	DATE	APP'D BY	DR NO.
RCE	01/15/98	RCE	20104-769