



NOTES:

1. 3Ø 4-WIRE SHOWN
2. 85,000 AMP SHORT-CKT RATING
3. 0.125" ALUMINUM CABINET
4. UL LISTED

MAE-2034UGBX

REVISIONS		
NO	DATE	BY
1	06/01/02	KAP
2	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

2000 AMP LAMINATED BUS ~ IN AC665414
UNDERGROUND ENTRANCE & EXIT

DR BY	DATE	APP'D BY	DR NO.
KAP	10/25/01	RCE	20104-771A

163
613