



NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. 65,000 AMP SHORT-CKT RATING
4. 0.100" ALUMINUM
5. UL LISTED

MAE

104
602

REVISIONS		
NO	DATE	BY
1	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

800 AMP BUS ARRANGEMENT ~
IN AC482510

DR BY KAP	DATE 06/05/02	APP'D BY RCE	DR NO. 20104-825A
--------------	------------------	-----------------	----------------------