



NOTES:

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. FOR 3Ø 3-WIRE, SEE DRAWING NO. 20104-891
4. 85,000 AMP SHORT-CKT RATING
5. 0.125" ALUMINUM
6. UL LISTED

105
604

GIN
MAE
NOR
TR
WE-1204-13
WPS-1204

REVISIONS		
NO	DATE	BY
1	03/30/90	RCE
2	01/24/94	RCE
3	06/05/02	KAP
4	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

1200 AMP BUS ARRANGEMENT ~
IN AC483614

DR BY	DATE	APP'D BY	DR NO.
RCE	12/15/88	RCE	20104-831