



NOTES:

WE-1204-13UG

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. FOR 3Ø 3-WIRE, SEE DRAWING NO. 20104-894
4. 85,000 AMP SHORT-CKT RATING
5. 0.125" ALUMINUM
6. UL LISTED

114
604

| REVISIONS | | |
|-----------|----------|-----|
| NO | DATE | BY |
| 1 | 01/24/94 | RCE |
| 2 | 07/30/02 | KAP |
| 3 | 02/01/07 | KRE |
| | | |
| | | |



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

**1200 AMP VERTICAL BUS ARRANGEMENT ~
IN AC485414 (LINE LUGS BY UTILITY)**

| | | | |
|-------|----------|----------|-----------|
| DR BY | DATE | APP'D BY | DR NO. |
| RCE | 03/01/90 | RCE | 20104-840 |