



**NOTES:**

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. FOR 3Ø 3-WIRE, SEE DRAWING NO. 20104-847.
4. 85,000 AMP SHORT-CKT RATING
5. 0.125" ALUMINUM
6. UL LISTED

114  
604

WE-1604-13UG

REVISIONS		
NO	DATE	BY
1	09/11/89	RCE
2	03/30/90	RCE
3	01/24/94	RCE
4	07/30/02	KAP
5	02/01/07	KRE



**GALVA-CLOSURE PRODUCTS CO.**

STOUGHTON, WISCONSIN

1600 AMP 4-WIRE, VERTICAL BUS ARRANGEMENT ~  
IN AC485414 (LINE LUGS BY UTILITY)

DR BY	DATE	APP'D BY	DR NO.
RCE	12/15/88	RCE	20104-842