



NOTES:

1. 3Ø 3-WIRE SHOWN
2. FOR 3Ø 4-WIRE, SEE DRAWING NO. 20104-842.
3. 85,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM
5. UL LISTED

WE-1603-8UG

REVISIONS		
NO	DATE	BY
1	03/30/90	RCE
2	01/24/94	RCE
3	07/31/02	KAP
4	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

1600 AMP 3-WIRE, VERTICAL BUS ARRANGEMENT ~
IN AC485414 (LINE LUGS BY UTILITY)

114
604

DR BY	DATE	APP'D BY	DR NO.
RCE	09/11/89	RCE	20104-847