



**NOTES:**

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. 85,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM
5. UL LISTED

MAE

105  
604

REVISIONS		
NO	DATE	BY
1	03/30/90	RCE
2	01/24/94	RCE
3	06/05/02	KAP
4	02/01/07	KRE



**GALVA-CLOSURE PRODUCTS CO.**

STOUGHTON, WISCONSIN

1600 AMP BUS ARRANGEMENT ~  
IN AC483614

DR BY	DATE	APP'D BY	DR NO.
RCE	10/19/89	RCE	20104-848