



NOTES:

1. 3Ø 4-WIRE SHOWN
2. 85,000 AMP SHORT-CKT RATING
3. 0.125" ALUMINUM
3. FOR 3Ø 3-WIRE, SEE
4. UL LISTED

MAE

122
604

| REVISIONS | | |
|-----------|----------|-----|
| NO | DATE | BY |
| 1 | 03/30/90 | RCE |
| 2 | 07/19/91 | RCE |
| 3 | 01/24/94 | RCE |
| 4 | 07/09/94 | RCE |
| 5 | 06/18/02 | KAP |
| 6 | 02/01/07 | KRE |



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

1600 AMP BUS ARRANGEMENT ~
IN AC484612 (WITH PT PLATE & 4 HOLE CT'S)

| | | | |
|-------|----------|----------|-----------|
| DR BY | DATE | APP'D BY | DR NO. |
| RCE | 10/11/89 | RCE | 20104-849 |