



**NOTES:**

1. 3Ø 4-WIRE SHOWN
2. 85,000 AMP SHORT-CKT RATING
3. 0.125" ALUMINUM
4. UL LISTED

MAE

REVISIONS		
NO	DATE	BY
2	06/19/02	KAP
2	02/01/07	KRE



**GALVA-CLOSURE PRODUCTS CO.**

STOUGHTON, WISCONSIN

2000 AMP LAMINATED BUS ARRANGEMENT ~  
IN AC664214 (WITH 10-7/8" CT BARS)

DR BY	DATE	APP'D BY	DR NO.
KAP	10/25/01	RCE	20104-867A

119  
613