



**NOTES:**

1. 3Ø 4-WIRE SHOWN
2. FOR 1Ø 3-WIRE, CENTER PHASE BUS IS OMITTED.
3. 85,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM
5. UL LISTED

MAE

REVISIONS		
NO	DATE	BY
1	12/02/96	RCE
2	06/13/02	KAP
3	02/01/07	KRE



**GALVA-CLOSURE PRODUCTS CO.**

STOUGHTON, WISCONSIN

3000 AMP LAMINATED BUS ARRANGEMENT ~  
IN AC724220 (WITH 10-7/8" CT BARS)

DR BY	DATE	APP'D BY	DR NO.
RCE	06/21/94	RCE	20104-876A

108  
613