



NOTES:

1. 3Ø 4-WIRE SHOWN
2. 85,000 AMP SHORT-CKT RATING
3. 0.125" ALUMINUM
4. UL LISTED

MAE

REVISIONS		
NO	DATE	BY
1	12/02/96	RCE
2	06/01/02 ALI	KAP
3	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

3000 AMP BUS ARRANGEMENT ~
IN AC725020 (WITH 10-7/8" CT BARS AND PT PLATE)

DR BY	DATE	APP'D BY	DR NO.
RCE	06/21/94	RCE	20104-877A

125
613