



NOTES:

1. 3Ø 3-WIRE SHOWN
2. FOR 1Ø 3-WIRE OR 3Ø 4-WIRE, SEE DRAWING NO. 20104-818.
3. 65,000 AMP SHORT-CKT RATING
4. 0.125" ALUMINUM
5. UL LISTED

WE-603-8UG

REVISIONS		
NO	DATE	BY
1	01/24/94	RCE
2	07/23/02	KAP
3	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

600 AMP VERTICAL BUS ARRANGEMENT ~
IN AC484612 (LINE LUGS BY UTILITY)

DR BY	DATE	APP'D BY	DR NO.
RCE	03/30/90	RCE	20104-885