



NOTES:

1. 3Ø 4-WIRE SHOWN
2. 85,000 AMP SHORT-C/KT RATING
3. 0.125" ALUMINUM
4. UL LISTED

MAE
MEN

REVISIONS		
NO	DATE	BY
1	01/24/94	RCE
2	07/06/94	RCE
3	06/18/02	KAP
4	02/01/07	KRE



GALVA-CLOSURE PRODUCTS CO.

STOUGHTON, WISCONSIN

1200 AMP BUS ARRANGEMENT ~
IN AC484612 (WITH PT PLATE AND 2 HOLE CT'S)

DR BY	DATE	APP'D BY	DR NO.
RCE	07/19/91	RCE	20104-897